



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-05113

Inspection Number: 03917371

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: AU - Garage

Scope of Work: New

Inspection Details

Inspection Date: 08/20/2024

Inspection Time: 10:30 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

1. Mechanically connect EGCs in all boxes with multiple cables 2. Make up multigang boxes