



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-09597
Inspection Number: 03917616

Building Inspection Report

Permit Information

Job Address: 9874 SILVER MAPLE RD HIGHLANDS RANCH
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 08/20/2024
Inspection Time: 12:22 PM
Inspection Type: Air Conditioner
Inspection Code: 55
Outcome: Approved
Inspected By: Richard Perrone
Charge Reinspection Fee: No