



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-05113

Inspection Number: 03919116

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: AU - Garage

Scope of Work: New

### Inspection Details

Inspection Date: 08/27/2024

Inspection Time: 10:58 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

### Comments

1. Strands cannot be trimmed at breaker in main panel at house or at main lugs in garage panel 2. Opener and high recep in corner both require GFCI protection-GFCI devices required to be readily accessible