



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-13750

Inspection Number: 03920525

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 3590 N STATE HIGHWAY 83 FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 09/06/2024

Inspection Time: 1:07 PM

Inspection Type: Driveway Preliminary

Inspection Code: 48

Outcome: Approved

Inspected By: June Amicucci

Charge Reinspection Fee: No

Comments

This driveway is for an extension off existing driveway.

New driveway will need 6 inches class six roadbase or equivalent. Driveway will need to be 12ft wide with any drainage that is needed.

There will also need to be a turnaround at the.

COMPLY WITH Douglas County Standards