



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-12238

Inspection Number: 03920820

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10122 ATLANTA ST PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/04/2024

Inspection Time: 2:03 PM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

Comments

** Ssbj from main neutral bar to supplemental neutral bar on enclosure must be sized per 250.104 (#4 copper or equivalent), correct and proceed, will check at final **