



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909  
Inspection Number: 03920833

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

**Job Address:** 9900 SARA GULCH CIR PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/04/2024  
**Inspection Time:** 10:53 AM  
**Inspection Type:** Exterior Lath  
**Inspection Code:** 33  
**Outcome:** Disapproved  
**Inspected By:** Rick Chadwick  
**Charge Reinspection Fee:** No

### Comments

Caulk around all penetrations