



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-13888
Inspection Number: 03922193

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10552 JAGUAR PT LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/10/2024
Inspection Time: 12:19 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No

Comments

1)only required recepts within 3' of sinks and counter top recepts permitted 20amp bath circuits 210.11(C)3
2)existing safety concerns mst bath CF box-NM connector, fill unused opening and ground. Must meet clearances per 410.10(D)
3)wiring incomplete 2nd vanity light
4)electric/remodel incomplete other 2 bathrooms
Note:per Doug Co amendments max 10 openings 15amp circuits and 12 openings 20amp circuits. If existing circuit(s) modified detailed written breakdown will be required