



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-12238

Inspection Number: 03923232

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10122 ATLANTA ST PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/16/2024

Inspection Time: 2:18 PM

Inspection Type: Shower Pan

Inspection Code: 65

Outcome: Disapproved

Inspected By: Duke Thompson

Charge Reinspection Fee: No

Comments

1. Leak at liner pan, retest
2. Install pre-slope underneath liner pan