



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-14605
Inspection Number: 03924601

Building Inspection Report

Permit Information

Job Address: 1295 BRAEWOOD AVE HIGHLANDS RANCH
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 09/19/2024
Inspection Time: 11:48 AM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Disapproved
Inspected By: Richard Perrone
Charge Reinspection Fee: No

Comments

1. Missing tamper resistant/locking caps for refrigerant lines at A/C.