



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711
Inspection Number: 03925045

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4848 RAINTREE CIR PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 09/20/2024
Inspection Time: 1:01 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Curt Elliott
Charge Reinspection Fee: No

Comments

1. Need working clearance for mech room panel
2. Label furnace disconnect
3. Need grommet for dishwasher cord passing through cabinet
4. Need access to electrical connections in hot tub