



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711
Inspection Number: 03925053

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4848 RAINTREE CIR PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 09/20/2024
Inspection Time: 9:44 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No

Comments

1. Paint exterior gasoline and PVC 2. Splash blocks at sill cocks 3. Seal gasoline penetration at exterior 4. Minimum 30" in front of water heater 5. Combustion air required for water heater