



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711  
Inspection Number: 03927851

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

**Job Address:** 4848 RAINTREE CIR PARKER  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 10/03/2024  
**Inspection Time:** 10:24 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Bond bushing required at isolated metallic raceway at spa or change to LFNC. Currently isolated between non metallic pieces. If keeping LFMC, adjust fitting at controller so insulated jacket is in connector

Note-GC on site installing bushing at DW