



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-05288
Inspection Number: 02647093

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 1064 COCHETOPA DR LARKSPUR
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 07/13/2006
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Troy Meissner
Charge Reinspection Fee: No