



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-12238

Inspection Number: 03929467

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

Job Address: 10122 ATLANTA ST PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

### Inspection Details

Inspection Date: 10/11/2024

Inspection Time: 2:23 PM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

### Comments

1) Ssbj from main neutral bar to supplemental neutral bar on enclosure must be sized per 250.104 (#4 copper or equivalent)

2) grommet required at dishwasher cord passing through cabinet per 422.16