



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-10909
Inspection Number: 03932185

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 3546 CASTLE BUTTE DR CASTLE ROCK
Job Type: Building
Description: AU - Barn
Scope of Work: New

Inspection Details

Inspection Date: 10/24/2024
Inspection Time: 9:28 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

4/0 URD with #2 EGC from pedestal to west side of barn in trench 2 ft+ deep with warning ribbon