



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909
Inspection Number: 03932575

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 9900 SARA GULCH CIR PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 10/25/2024
Inspection Time: 1:59 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Ok to insulate pending frame approval. Recall when outdoor bar is wired.

Note-UFER in east wall of bar area. Must remain accessible

****Service upgrade for house requires separate permit. Currently (2)-150s and panel changed to (2)-200s. Provide voltage drop calc and all provisions of 225.41 will be required at house due to distribution equipment change. DC amendment requires voltage drop on dwelling feeders be 3% or less****