



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909
Inspection Number: 03933423

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 9900 SARA GULCH CIR PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 10/30/2024
Inspection Time: 1:47 PM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: Richard Miller
Charge Reinspection Fee: No