



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-13888
Inspection Number: 03935877

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10552 JAGUAR PT LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 11/14/2024
Inspection Time: 9:48 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Brian Schroder
Charge Reinspection Fee: No

Comments

Bathroom number three of three