



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-07644
Inspection Number: 03939054

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10906 SHADOW PINES RD PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/02/2024
Inspection Time: 1:26 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release: Yes
Provider: CORE
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Note-UFER located in NW corner of gym next to main gas pipe entry-must remain accessible
For final-working space at emergency disc required to be as level as possible-110.26