



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-13750

Inspection Number: 03939939

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

Job Address: 3590 N STATE HIGHWAY 83 FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 12/04/2024

Inspection Time: 10:43 AM

Inspection Type: Foundation Insulation

Inspection Code: 114

Outcome: Approved

Inspected By: Clayton Rodeback

Charge Reinspection Fee: No