



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-07644
Inspection Number: 03941864

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10906 SHADOW PINES RD PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/13/2024
Inspection Time: 8:32 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Curt Elliott
Charge Reinspection Fee: No