Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-07644
Inspection Number: 03941866

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10906 SHADOW PINES RD PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/13/2024
Inspection Time: 9:00 AM
Inspection Type: Rough Energy Compliance
Inspection Code: 129
Outcome: Approved
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No