



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 24-10372  
Inspection Number: 03946556

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

**Job Address:** 10245 BANE BERRY PL HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 01/14/2025  
**Inspection Time:** 2:15 PM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

- 1)right mst bath recep inoperable
- 2)breaker lock req at hood per 110.25