Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-10372
Inspection Number: 03946557

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10245 BANEBERRY PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/14/2025
Inspection Time: 12:18 PM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

Water temperatures to be adjusted by end of business today, walked with the builder. Freestanding tub to be adjusted at the 1070.
Water in the main house is 135 degrees. Adjust accordingly. Find a building approved pending final electric approval.