



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-10372
Inspection Number: 03946558

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10245 BANE BERRY PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/14/2025
Inspection Time: 2:00 PM
Inspection Type: Final Energy Compliance
Inspection Code: 109
Outcome: Approved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

This is a remodel job, existing HVAC