



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 06-00901  
Inspection Number: 02661095

## Building Inspection Report

Code Reviewed Under: 2003 IRC

### Permit Information

**Job Address:** 784 INTERNATIONAL ISLE DR CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/13/2006  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Disapproved  
**Inspected By:** Wayne Elmore  
**Charge Reinspection Fee:** No

### Comments

res