



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 06-02653  
Inspection Number: 02661775

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 12868 LOST CANYON TRL PARKER  
**Job Type:** Building  
**Description:** AU - Other - ADDITION  
**Scope of Work:** Addition

### Inspection Details

**Inspection Date:** 09/15/2006  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric Partial  
**Inspection Code:** 21  
**Outcome:** Approved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No