



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 06-00901
Inspection Number: 02668791

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 784 INTERNATIONAL ISLE DR CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 10/18/2006
Inspection Time: 12:00 AM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No