



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 06-04992
Inspection Number: 02674589

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 6679 TWISTED OAK DR CASTLE PINES
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 11/17/2006
Inspection Time: 12:00 AM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No