



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-13750

Inspection Number: 03985058

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 3590 N STATE HIGHWAY 83 FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 08/08/2025

Inspection Time: 4:15 PM

Inspection Type: Exterior Underground Gas Line

Inspection Code: 32

Outcome: Disapproved

Inspected By: Fredrick Mooney

Charge Reinspection Fee: No

Comments

Gas line inspected for new custom, line to future barn. Trenching incomplete to supply, ends at septic tank. Ok to backfill from septic tank to terminations. Recall second half when ready.