



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-13750

Inspection Number: 03990136

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 3590 N STATE HIGHWAY 83 FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 09/09/2025

Inspection Time: 3:05 PM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Approved

Inspected By: Brian Schroder

Charge Reinspection Fee: No